

Test Report Number:	FTS26AR-00442E	Total Page(s): 31
Applicant Name:	MIGUELEZ & DEL CUETO DISTRIBUCION SL CIF: B75441295	
Applicant Address:	PARQUE DE LOS LIRIOS N7 PRIMERO OFICINA 2 26009 LOGRONO LA RIOJA SPAIN	
Trade Mark	MC Technology, KENRO climate solutions	
Test item:	ENERGY RECOVERY VENTILATOR	
Model / Type Reference:	ZX10190I, ZX10250I	
Date of Issue:	2026-02-02	
Testing Laboratory:	Guangdong Future Test Services Co., Ltd.	
Test Specification:	EN IEC 55014-1:2021 EN IEC 55014-2:2021 EN IEC 61000-3-2:2019+A1:2021+A2:2024 EN 61000-3-3:2013+A1:2019+A2:2021	
Test Result:	Passed	
Compiled by:	Reviewed by:	
2026-02-02 George Wu	<i>George Wu</i>	2026-02-02 Gordon Xie <i>Gordon Xie</i>
<i>Date</i> <i>Name</i>	<i>Signature</i>	<i>Date</i> <i>Name</i> <i>Signature</i>
Remark:		
N/A		
<p>The duplication of this report or parts of it and its use for advertising purposes is only allowed with permission of the testing laboratory. This report contains the result of the examination of the product sample submitted by the applicant. A general statement concerning the quality of the products from the series manufacture cannot be derived therefore.</p>		

Test Summary

- 6.1.1 Harmonics Current Emission on AC Mains**
RESULT: Pass
- 6.1.2 Voltage Changes, Voltage Fluctuations and Flicker**
RESULT: Pass
- 6.1.3 Terminal Continuous Disturbance Voltage**
RESULT: Pass
- 6.1.4 Disturbance Power on AC Mains**
RESULT: Pass
- 6.1.5 Discontinuous Disturbance Voltage on AC mains(Click)**
RESULT: Pass
- 7.2.1 Radio-frequency Common Mode / Conducted Susceptibility (CS)**
RESULT: Pass
- 7.3.1 Electrical Fast Transients (EFT)**
RESULT: Pass
- 7.3.2 Surge**
RESULT: Pass
- 7.3.3 Electrostatic Discharges (ESD)**
RESULT: Pass
- 7.4.1 Voltage Dips and Interruptions**
RESULT: Pass

Contents

1. General Remarks	4
1.1 Complementary Materials.....	4
2. Measurement Uncertainty	4
3. Test Sites	4
3.1 Test Facilities	4
3.2 List of Test and Measurement Instruments	4
4. General Product Information	5
4.1 Product Function and Intended Use	5
4.2 Ratings and System Details.....	5
4.3 Independent Operation Modes	5
4.4 Noise Generating and Noise Suppressing Parts	6
4.5 Submitted Documents	6
5. Test Set-up and Operation Modes	6
5.1 Principle of Configuration Selection.....	6
5.2 Physical Configuration for Testing	6
5.3 Test Operation and Test Software.....	6
5.4 Special Accessories and Auxiliary Equipment.....	7
5.5 Countermeasures to achieve EMC Compliance.....	7
6. Test Results Emission	8
6.1 Emission in the Frequency Range up to 30 MHz	8
6.1.1 Harmonics Current Emission on AC Mains	8
6.1.2 Voltage Changes, Voltage Fluctuations and Flicker	10
6.1.3 Terminal Continuous Disturbance Voltage.....	11
6.1.4 Disturbance Power on AC Mains	13
6.1.5 Discontinuous Disturbance Voltage on AC mains(Click)	15
7. Test Results Immunity	17
7.1 Immunity requirements	17
7.2 Continuous Disturbances.....	18
7.2.1 Radio-frequency Common Mode / Conducted Susceptibility (CS)	18
7.3 Transient Disturbances.....	20
7.3.1 Electrical Fast Transients (EFT).....	20
7.3.2 Surge	22
7.3.3 Electrostatic Discharges (ESD)	24
7.4 Power Supply Alterations.....	26
7.4.1 Voltage Dips and Interruptions	26
8. The photos of test setting	28

1. General Remarks

When applying the basic standards in this test report, please refer to the applied generic or product family standards for edition information:
 For dated basic standards, only the edition cited applies. For undated basic standards, the latest edition (including any amendments) applies.

1.1 Complementary Materials

All attachments are integral parts of this test report. This applies especially to the following appendix:

- Appendix 1: Test result.
- Appendix 2: Photo of EUT
- Appendix 3: List of Test and Measurement Equipment

2. Measurement Uncertainty

Test Item	Uncertainty
Uncertainty for Conduction emission test	3.12dB
Uncertainty for Radiation Emission test	3.56dB

Note: This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of $k=2$.

3. Test Sites

3.1 Test Facilities

A. Guangdong Future Test Services Co., Ltd.
 Add: Room A01、A02、A03, No.228, Min'an South Road, Xiaolan, Zhongshan, Guangdong, China

3.2 List of Test and Measurement Instruments

Table 1: List of Test and Measurement Equipment

Refer to attached Appendix 3.

4. General Product Information

The new submitted sample are energy recovery ventilator ordinary household electrical appliances.

Model list:

Model	Rated input	Rated power	PCB	Motor
ZX10190I	220-240V~, 50/60Hz	87W	PCB1	Motor1
ZX10250I		162W		Motor2

Remark:

All model has same PCB and rated power except for model name and motor.

According to the above information, all tests were performed on following models **ZX10190I** and **ZX10250I**.

4.1 Product Function and Intended Use

Refer to Technical Documentation and User Manual

4.2 Ratings and System Details

Type designation:	Refer to section 4
Rated input:	Refer to section 4
Rated power:	Refer to section 4
Protection class:	Class I
Ports:	AC mains, maximum length of the control line < 2m
Cables:	Unshielded

Refer to the Technical Documentation for further information.

4.3 Independent Operation Modes

The basic operation modes are:

- A. Max power
- B. Min power
- C. Auto mode
- D. OFF

Refer to the user manual for further information.

4.4 Noise Generating and Noise Suppressing Parts

Refer to the Technical Documentation for further information.

4.5 Submitted Documents

Difference Declaration
Circuit Diagram
PCB Layout
User Manual
Label

5. Test Set-up and Operation Modes

5.1 Principle of Configuration Selection

Emission: The equipment under test (EUT) was configured to measure its highest possible radiation level. The test modes were adapted accordingly in reference to the instructions for use.

Immunity: The equipment under test (EUT) was configured to have its highest possible susceptibility against the tested phenomena. The test modes were adapted accordingly in reference to the instructions for use.

5.2 Physical Configuration for Testing

Refer to relative paragraphs of this test report.

5.3 Test Operation and Test Software

Refer to test setup in chapter 6 and chapter 7.

5.4 Special Accessories and Auxiliary Equipment

Product: ERV TOUCHSCREEN CONTROLLER

Model: YT040H01

Manufacturer: DWIN TECHNOLOGY

The auxiliary equipment is provided by the applicant.

5.5 Countermeasures to achieve EMC Compliance

No additional countermeasures to the submitted test sample(s) were employed to achieve compliance.

6. Test Results Emission

6.1 Emission in the Frequency Range up to 30 MHz

6.1.1 Harmonics Current Emission on AC Mains


RESULT:**Pass****Test Specification**

Basic standard	:	EN IEC 61000-3-2:2019+A1:2021+A2:2024
Measurement equipment requirement	:	IEC 61000-4-7
Measured harmonics	:	1 – 40
Equipment class	:	A
Limits	:	Clause 7.2

Test Setup

Date of testing	:	Refer to Appendix 1
Input voltage	:	AC 230V,50Hz
Operation mode	:	A
Test observation period	:	2.5min
Temperature	:	23°C
Humidity	:	51%
Air pressure	:	101kPA

Test Connection Diagram



For measurement results, please refer to the attached appendix 1

6.1.2 Voltage Changes, Voltage Fluctuations and Flicker

RESULT:

Pass


Test Specification

Basic standard : EN 61000-3-3:2013+A1:2019+A2:2021
 Measurement equipment requirement : IEC 61000-4-15
 Limits : EN 61000-3-3:2013+A1:2019+A2:2021, Clause 5

Test Setup

Date of testing : Refer to Appendix 1
 Input voltage : AC 230V,50Hz
 Operation mode : A
 Test observation period : 120min
 Temperature : 22°C
 Humidity : 50%
 Air pressure : 101kPA

Test Connection Diagram



For measurement results, please refer to the attached appendix 1

6.1.3 Terminal Continuous Disturbance Voltage

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-1:2021, Clause 5
Port	: AC Mains, control line
Frequency range of Mains	: 150kHz-30MHz
Test site	: Shielded Room
Limits	: EN IEC 55014-1:2021, Clause 4.3.3.6, Table 5

Test Setup

Date of testing	: Refer to Appendix 1
Input voltage	: Refer to Appendix 1
Operation mode	: A (worst mode)
Test Ports	: AC Mains, control line
Test configuration	: Table-top
Temperature	: Refer to Appendix 1
Humidity	: Refer to Appendix 1
Air pressure	: Refer to Appendix 1

Test Connection Diagram



Test Result

Measurement uncertainty: 3.12 dB ($k=2$, $\sigma=95\%$)

If the result of the measurement with the Quasi Peak detector is below the Average limit, the measurement with Average Detector will be omitted.

Disturbances other than those mentioned are small or not detectable.

For measurement results, please refer to the attached appendix 1.

6.1.4 Disturbance Power on AC Mains

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-1:2021, Clause 5.3.3
Port	: AC Mains, control port
Frequency range of Mains	: 30MHz-300MHz
Test site	: Shielded Room
Limits	: EN IEC 55014-1:2021, Clause 4.3.4.4, Table 7, 8

Test Setup

Date of testing	: Refer to Appendix 1
Input voltage	: Refer to Appendix 1
Operation mode	: A (worst mode)
Test Ports	: AC Mains, control port
Test configuration	: Table-top
Temperature	: Refer to Appendix 1
Humidity	: Refer to Appendix 1
Air pressure	: Refer to Appendix 1

Test Connection Diagram



Test Result

Measurement uncertainty: 3.26dB ($k=2$, $\sigma=95\%$)

If the result of the measurement with the Quasi Peak detector is below the Average limit, the measurement with Average Detector has been omitted.

The power cord had been extended to a length of 6m and routed through an absorber clamp. The clamp was moved along the cable to find the maximal emission.

Disturbances other than those mentioned are small or not detectable.

For measurement results, please refer to the attached appendix 1.

6.1.5 Discontinuous Disturbance Voltage on AC mains(Click)

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-1:2021, Annex C
Port	: AC Mains
Frequency range of Mains	: 150kHz-30MHz
Test site	: Shielded Room
Limits	: EN IEC 55014-1:2021, Clause 4.4.2, Table 5

Test Setup

Date of testing	: Refer to Appendix 1
Input voltage	: Refer to Appendix 1
Operation mode	: C
Test Ports	: AC Mains
Test configuration	: Table-top
Temperature	: Refer to Appendix 1
Humidity	: Refer to Appendix 1
Air pressure	: Refer to Appendix 1

Test Connection Diagram



Test Result

Disturbances other than those mentioned are small or not detectable.

For measurement results, please refer to the attached appendix 1.

7. Test Results Immunity

7.1 Immunity requirements

The EUT contains electronic control circuitry with no internal clock frequency or oscillator frequency higher than 15MHz, according to EN IEC 55014-2:2021, clause 4, the EUT is a category II appliance.

Apparatus of the category II shall fulfill the requirement of:

Radio-frequency Common Mode / Conducted Susceptibility (CS)	Criterion A
Electrical Fast Transients (EFT)	Criterion B
Surges	Criterion B
Electrostatic Discharge (ESD)	Criterion B
Voltage Dips	Criterion C

7.2 Continuous Disturbances

7.2.1 Radio-frequency Common Mode / Conducted Susceptibility (CS)

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-2:2021
Basic standard	: IEC 61000-4-6
Characteristics of the test generator	
Output impedance	: 50 Ω
Amplitude modulation	: AM 80 %, 1 kHz sine-wave
Frequency bandwidth	: 150kHz to 230MHz
Frequency step	: 1% with 1 s dwell time
Performance criterion	: A

Test Setup

Date of testing	: 18 Dec, 2025
Input voltage	: AC 230V, 50Hz
Operation mode	A
Temperature	: 23°C
Humidity	: 51%
Air pressure	: 101kPA

Test Connection Diagram



Test Result

Table 2: Immunity against Radio-frequency Common Mode / Conducted Susceptibility (CS)

Coupling port	Application	Strength	Result	Remarks
AC power port	CDN-M3	3V(r.m.s)	Pass	A
DC power port*	N/A	N/A	N/A	
Signal/Control lines*	N/A	N/A	N/A	
note: A:Equipment operated as intended, no degradation of function. *:The control cable is less than 2m, so the test on control terminal is not applicable.				

7.3 Transient Disturbances

7.3.1 Electrical Fast Transients (EFT)

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-2:2021
Basic standard	: IEC 61000-4-4
Rise time	: 5 ns
Duration	: 50 ns
Repetition Freq	: 5 kHz
Test duration	: 2 minute per level & polarity
Performance criterion	: B

Test Setup

Date of testing	: 18 Dec, 2025
Input voltage	: AC 230V, 50Hz
Operation mode	A
Temperature	: 23°C
Humidity	: 51%
Air pressure	: 101kPA

Test Connection Diagram



Test Result

Table 3: Immunity against Electrical Fast Transients (EFT)

Coupling point	Application	Level (kV)	Result	Remark
AC power port	Coupling network	±1	Pass	A
DC power port*	Coupling network	N/A	N/A	
Signal lines*	Coupling clamp	N/A	N/A	
Control lines	Coupling clamp	N/A	N/A	
note: A:Equipment operated as intended, no degradation of function. *:The control cable is less than 2m, so the test on control terminal is not applicable.				

7.3.2 Surge

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-2:2021
Basic standard	: IEC 61000-4-5
Pulse form	: $T_r/T_h=1.2/50\mu s$
Coupling	Coupling Network for AC Mains
Coupling phases	: $90^\circ, 270^\circ$
Number of surges / polarity /phase angle	: 5
Repetition rate	: 60s
Performance criterion	: B

Test Setup

Date of testing	: 18 Dec, 2025
Input voltage	: AC 230V, 50Hz
Operation mode	A
Temperature	: $23^\circ C$
Humidity	: 51%
Air pressure	: 101kPA

Test Connection Diagram



Test Result

Table 4: Surge Immunity Tests

Coupling point	Application	Level (kV)	Polarity	Remark
AC power port	Between phase and neutral	1	+	Applied, *)
		1	-	Applied, *)
AC power port	Between phase and earth	2	+	Applied, *)
		2	-	Applied, *)
AC power port	Between neutral and earth	2	+	Applied, *)
		2	-	Applied, *)

*) Remark: No degradation was found.

7.3.3 Electrostatic Discharges (ESD)

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-2:2021
Basic standard	: IEC 61000-4-2
Charge voltage	: ±4kV (contact, VCP, HCP) ±8kV (air discharge)
Number of discharges	: > 10
Polarity	: Positive / Negative
Performance criterion	: B

Test Setup

Date of testing	: 18 Dec, 2025
Input voltage	: AC 230V, 50Hz
Operation mode	: A
Temperature	: 23°C
Humidity	: 51%
Air pressure	: 101kPA

Test Connection Diagram



Test Result

Table 5: Electrostatic Discharge

Direct discharges			
Air discharges Discharge location	Air discharge voltage (kV)	Polarity	Remark
Non-conductive parts	8	+/-	Applied, *)
Contact discharges Discharge location	Contact discharge voltage (kV)	Polarity	Remark
Conductive parts	4	+/-	Applied, *)
Indirect discharges			
Contact discharges Discharge location	Contact discharge voltage (kV)	Polarity	Remark
HCP	4	+/-	Applied, *)
VCP	4	+/-	Applied, *)

*) Remark: No degradation was found.

7.4 Power Supply Alterations

7.4.1 Voltage Dips and Interruptions

RESULT:

Pass


Test Specification

Family standard	: EN IEC 55014-2:2021
Basic standard	: IEC 61000-4-11
Phase angle	: 0°
Test level	Refer to table 6
Number of voltage dips/ interruptions	: 3
Interval	: >10s
Performance criterion	: C

Test Setup

Date of testing	: 18 Dec, 2025
Input voltage	: AC 230V, 50Hz/AC 230V, 60Hz
Operation mode	A
Temperature	: 23°C
Humidity	: 51%
Air pressure	: 101kPA

Test Connection Diagram:



Test Result


Table 6: Voltage Dip and Interruptions Immunity

Interruptions			
Test level (% Ut)	Duration (cycle)	Number of interruptions	Result
0	0.5	3	Applied, *)
Voltage dips			
Test level (% Ut)	Duration (cycle)	Number of voltage dips	Result
40	10/12	3	Applied, *)
70	25/30	3	Applied, *)

*) Remark: No degradation was found.

8. The photos of test setting

Harmonics and flick on AC Mains:




Terminal Continuous Disturbance Voltage:




Disturbance Power:



Radio-frequency Common Mode / Conducted Susceptibility (CS):




Electrical Fast Transients (EFT)/ Voltage Dip and Interruptions:



Electrostatic Discharges (ESD):



Surge:




California Instruments
San Diego, California

Harmonics – Class-A per IEC 61000-3-2:2018+A1:2020+A2:2024(Run time)


EUT: ENERGY RECOVERY VENTILATOR
 Test category: Class-A (European limits)
 Test date: 2025/12/17 Start time: 16:44:24 End time: 16:47:05
 Test duration (min): 2.5 Data file name: H-001235.cts_data
 Comment: ZX10190I
 Customer: Max power

Test Result: Pass Source qualification: Normal

Current & voltage waveforms



Harmonics and Class A limit line European Limits



Test result: Pass Worst harmonics H9-25.4% of 150% limit, H9-37.6% of 100% limit

California Instruments
San Diego, California

Current Test Result Summary (Run time)

EUT: ENERGY RECOVERY VENTILATOR
 Test category: Class-A (European limits)
 Test date: 2025/12/17 Start time: 16:44:24 End time: 16:47:05
 Test duration (min): 2.5 Data file name: H-001235.cts_data
 Comment: ZX101901
 Customer: Max power

Tested by: George Wu
 Test Margin: 100

Test Result: Pass Source qualification: Normal
 THCA(A): 0.529 I-THD(%): 138.8 POHC(A): 0.036 POHC Limit(A): 0.251

Highest parameter values during test:

V_RMS (Volts): 230.47 Frequency(Hz): 50.00
 I_Peak (Amps): 2.090 I_RMS (Amps): 0.658
 I_Fund (Amps): 0.381 Crest Factor: 3.185
 Power (Watts): 85.1 Power Factor: 0.562

Harm#	Harms(avg)	100%Limit	%of Limit	Harms(max)	150%Limit	%of Limit	Status
2	0.002	1.080	N/A	0.002	1.620	N/A	Pass
3	0.338	2.300	14.7	0.343	3.450	9.9	Pass
4	0.001	0.430	N/A	0.002	0.645	N/A	Pass
5	0.286	1.140	25.1	0.290	1.710	16.9	Pass
6	0.000	0.300	N/A	0.001	0.450	N/A	Pass
7	0.220	0.770	28.6	0.223	1.155	19.3	Pass
8	0.000	0.230	N/A	0.001	0.345	N/A	Pass
9	0.151	0.400	37.6	0.153	0.600	25.4	Pass
10	0.001	0.184	N/A	0.001	0.276	N/A	Pass
11	0.089	0.330	26.8	0.090	0.495	18.2	Pass
12	0.001	0.153	N/A	0.001	0.230	N/A	Pass
13	0.043	0.210	20.5	0.044	0.315	14.0	Pass
14	0.001	0.131	N/A	0.001	0.197	N/A	Pass
15	0.024	0.150	15.8	0.024	0.225	10.8	Pass
16	0.001	0.115	N/A	0.001	0.173	N/A	Pass
17	0.025	0.132	18.8	0.025	0.198	12.7	Pass
18	0.000	0.102	N/A	0.001	0.153	N/A	Pass
19	0.024	0.118	20.3	0.024	0.178	13.7	Pass
20	0.000	0.092	N/A	0.000	0.138	N/A	Pass
21	0.019	0.107	17.6	0.019	0.161	12.0	Pass
22	0.000	0.084	N/A	0.001	0.125	N/A	Pass
23	0.014	0.098	14.6	0.015	0.147	9.9	Pass
24	0.000	0.077	N/A	0.001	0.115	N/A	Pass
25	0.013	0.090	14.0	0.013	0.135	9.5	Pass
26	0.001	0.071	N/A	0.001	0.107	N/A	Pass
27	0.012	0.083	14.2	0.012	0.125	9.8	Pass
28	0.002	0.066	N/A	0.002	0.099	N/A	Pass
29	0.011	0.078	13.6	0.011	0.116	9.3	Pass
30	0.001	0.061	N/A	0.001	0.092	N/A	Pass
31	0.010	0.073	13.3	0.010	0.109	9.1	Pass
32	0.002	0.058	N/A	0.002	0.086	N/A	Pass
33	0.009	0.068	13.6	0.010	0.102	9.3	Pass
34	0.001	0.054	N/A	0.001	0.081	N/A	Pass
35	0.008	0.064	13.0	0.009	0.096	8.9	Pass
36	0.000	0.051	N/A	0.000	0.077	N/A	Pass
37	0.007	0.061	11.3	0.007	0.091	7.7	Pass
38	0.000	0.048	N/A	0.000	0.073	N/A	Pass
39	0.006	0.058	10.9	0.006	0.087	7.4	Pass
40	0.001	0.046	N/A	0.001	0.069	N/A	Pass

California Instruments
San Diego, California

Voltage Source Verification Data (Run time)

EUT: ENERGY RECOVERY VENTILATOR
 Test category: Class-A (European limits)
 Test date: 2025/12/17
 Test duration (min): 2.5
 Comment: ZX101901
 Customer: Max power

Tested by: George Wu
 Test Margin: 100
 End time: 16:47:05
 Start time: 16:44:24
 Data file name: H-001235.cts_data

Test Result: Pass Source qualification: Normal

Highest parameter values during test:

Voltage (Vrms): 230.47
 I_Peak (Amps): 2.090
 I_Fund (Amps): 0.381
 Power (Watts): 85.1

Frequency(Hz): 50.00
 I_RMS (Amps): 0.658
 Crest Factor: 3.185
 Power Factor: 0.562

Harm#	Harmonics V-rms	Limit V-rms	% of Limit	Status
2	0.063	0.461	13.61	OK
3	0.510	2.074	24.60	OK
4	0.070	0.461	15.10	OK
5	0.060	0.922	6.47	OK
6	0.036	0.461	7.80	OK
7	0.100	0.691	14.49	OK
8	0.012	0.461	2.51	OK
9	0.051	0.461	11.17	OK
10	0.016	0.461	3.39	OK
11	0.045	0.230	19.59	OK
12	0.015	0.230	6.56	OK
13	0.031	0.230	13.48	OK
14	0.009	0.230	3.89	OK
15	0.021	0.230	9.17	OK
16	0.005	0.230	2.30	OK
17	0.021	0.230	8.92	OK
18	0.009	0.230	3.70	OK
19	0.026	0.230	11.08	OK
20	0.035	0.230	15.26	OK
21	0.023	0.230	10.15	OK
22	0.006	0.230	2.58	OK
23	0.017	0.230	7.17	OK
24	0.003	0.230	1.22	OK
25	0.016	0.230	6.89	OK
26	0.003	0.230	1.22	OK
27	0.019	0.230	8.42	OK
28	0.004	0.230	1.65	OK
29	0.015	0.230	6.67	OK
30	0.003	0.230	1.20	OK
31	0.014	0.230	6.08	OK
32	0.002	0.230	0.99	OK
33	0.016	0.230	6.76	OK
34	0.003	0.230	1.21	OK
35	0.015	0.230	6.54	OK
36	0.003	0.230	1.16	OK
37	0.011	0.230	4.88	OK
38	0.003	0.230	1.45	OK
39	0.011	0.230	4.88	OK
40	0.020	0.230	8.83	OK

California Instruments
San Diego, California

Flicker Test Summary per IEC61000-3-3:2013+A1:2017+A2:2021 (Run time)

EUT: ENERGY RECOVERY VENTILATOR
 Test category: All parameters (European limits)
 Test date: 2025/12/18 Start time: 11:28:04 End time: 13:29:37
 Test duration (min): 120 Data file name: F-001160.cts_data
 Comment: ZX10190I
 Customer: Auto mode

Tested by: George Wu
 Test Margin: 100

Test Result: Pass


Status: Test Completed

Pst_i and limit line

European Limits



Plt and limit line




Parameter values recorded during the test:

Vrms at the end of test (Volt):	230.45		
T-max (mS):	0	Test limit (mS):	500.0 Pass
Highest dc (%):	0.00	Test limit (%):	3.30 Pass
Highest dmax (%):	0.00	Test limit (%):	4.00 Pass
Highest Pst (10 min. period):	0.188	Test limit:	1.000 Pass
Highest Plt (2 hr. period):	0.154	Test limit:	0.650 Pass



Guangdong Future Test Services co., Ltd.
 Tel: +86-760-22185188
 Fax: +86-760-22582768

Conducted Emission Measurement



Site: LAB Phase: **L1** Temperature: 23.6
 Limit: EN55014-1 Conduction(QP) Power: AC230V/50Hz Humidity: 42 %
 EUT: ENERGY RECOVERY VENTILATOR Atmosphere Pressure: 101.1KPa
 M/N: ZX10190I
 Mode: Max power
 Note:


No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV	Limit dBuV	Over dB	Detector	Comment
1		0.3695	31.09	20.05	51.14	58.51	-7.37	QP	
2		0.3695	24.22	20.05	44.27	49.27	-5.00	AVG	
3		0.4151	27.03	20.05	47.08	57.55	-10.47	QP	
4		0.4151	21.03	20.05	41.08	48.01	-6.93	AVG	
5		0.6900	27.07	19.83	46.90	56.00	-9.10	QP	
6		0.6900	20.25	19.83	40.08	46.00	-5.92	AVG	
7		1.2389	26.07	19.27	45.34	56.00	-10.66	QP	
8		1.2389	20.05	19.27	39.32	46.00	-6.68	AVG	
9		2.2559	26.47	19.30	45.77	56.00	-10.23	QP	
10		2.2559	21.10	19.30	40.40	46.00	-5.60	AVG	
11		3.1650	27.15	19.38	46.53	56.00	-9.47	QP	
12	*	3.1650	21.91	19.38	41.29	46.00	-4.71	AVG	

*:Maximum data x:Over limit !:over margin (Reference Only)



Guangdong Future Test Services co., Ltd.
 Tel: +86-760-22185188
 Fax: +86-760-22582768

Conducted Emission Measurement



Site: LAB Phase: **N** Temperature: 23.6
 Limit: EN55014-1 Conduction(QP) Power: AC230V/50Hz Humidity: 42 %
 EUT: ENERGY RECOVERY VENTILATOR Atmosphere Pressure: 101.1KPa
 M/N: ZX10190I
 Mode: Max power
 Note:


No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV	Limit dBuV	Over dB	Detector	Comment
1		0.3704	31.17	20.06	51.23	58.49	-7.26	QP	
2		0.3704	24.01	20.06	44.07	49.24	-5.17	AVG	
3		0.8339	25.21	19.59	44.80	56.00	-11.20	QP	
4		0.8339	19.30	19.59	38.89	46.00	-7.11	AVG	
5		1.9454	25.98	19.29	45.27	56.00	-10.73	QP	
6		1.9454	20.53	19.29	39.82	46.00	-6.18	AVG	
7		3.1875	28.56	19.33	47.89	56.00	-8.11	QP	
8	*	3.1875	22.55	19.33	41.88	46.00	-4.12	AVG	
9		3.6600	27.95	19.35	47.30	56.00	-8.70	QP	
10		3.6600	21.93	19.35	41.28	46.00	-4.72	AVG	
11		4.3125	27.33	19.36	46.69	56.00	-9.31	QP	
12		4.3125	21.40	19.36	40.76	46.00	-5.24	AVG	

*:Maximum data x:Over limit !:over margin (Reference Only)



Guangdong Future Test Services co., Ltd.
 Tel: +86-760-22185188
 Fax: +86-760-22582768

Conducted Emission Measurement



Site: LAB Phase: **L1** Temperature: 24
 Limit: EN55014 Current clamp (QP) Power: AC230V/50Hz Humidity: 52 %
 EUT: ENERGY RECOVERY VENTILATOR Atmosphere Pressure: 101.1KPa
 M/N: ZX10190I
 Mode: max power
 Note:

No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuA	Limit dBuA	Over dB	Detector	Comment
1		0.1748	19.94	3.26	23.20	38.73	-15.53	QP	
2		0.1748	12.80	3.26	16.06	28.73	-12.67	AVG	
3		0.2714	20.71	-0.49	20.22	35.07	-14.85	QP	
4		0.2714	13.50	-0.49	13.01	25.07	-12.06	AVG	
5		0.3930	20.51	-3.03	17.48	32.00	-14.52	QP	
6	*	0.3930	13.74	-3.03	10.71	22.00	-11.29	AVG	
7		0.5909	18.46	-5.72	12.74	30.00	-17.26	QP	
8		0.5909	14.06	-5.72	8.34	20.00	-11.66	AVG	
9		0.8474	20.21	-7.39	12.82	30.00	-17.18	QP	
10		0.8474	14.85	-7.39	7.46	20.00	-12.54	AVG	
11		1.4865	20.42	-8.68	11.74	30.00	-18.26	QP	
12		1.4865	13.36	-8.68	4.68	20.00	-15.32	AVG	

*:Maximum data x:Over limit !:over margin (Reference Only)

Site LAB Temperature: 25
 Limit: EN55014-1 Clamp(QP) Humidity: 52 %
 EUT: ENERGY RECOVERY VENTILATOR Power: AC230V/50Hz Atmosphere Pressure: 101.1KPa
 M/N: ZX10190I
 Mode: max power
 Note: control line near controller

No.	Mk.	Freq.	Reading	Correct	Measure-	Limit	Over	Detector	Position	
			Level	Factor	ment				cm	Comment
		MHz	dBpW	dB	dBpW	dBpW	dB			
14		189.5469	-4.38	23.61	19.23	40.91	-21.68	AVG		
15		191.6148	9.05	23.63	32.68	51.18	-18.50	QP		
16		191.6148	6.89	23.63	30.52	40.99	-10.47	AVG		
17		202.4559	5.14	23.65	28.79	51.34	-22.55	QP		
18		202.4559	-3.80	23.65	19.85	41.39	-21.54	AVG		
19		206.3892	12.09	23.53	35.62	51.08	-15.46	QP		
20		206.3892	6.56	23.53	30.09	41.53	-11.44	AVG		
21		231.8487	2.95	24.38	27.33	49.43	-22.10	QP		
22		231.8487	-4.78	24.38	19.60	42.48	-22.88	AVG		

*:Maximum data x:Over limit !:over margin (Reference Only)

Final Factor=probe factor+Cable loss.

File :1\Data :#10

Page: 2

Engineer Signature:


California Instruments
San Diego, California

Harmonics – Class-A per IEC 61000-3-2:2018+A1:2020+A2:2024(Replay)


EUT: ENERGY RECOVERY VENTILATOR
 Test category: Class-A (European limits)
 Test date: 2025/11/19 Start time: 17:06:46 End time: 17:09:27
 Test duration (min): 2.5 Data file name: H-001237.cts_data
 Comment: ZX10250I
 Customer: Max power

Test Result: Pass Source qualification: Normal

Current & voltage waveforms



Harmonics and Class A limit line European Limits



Test result: Pass Worst harmonics H9-33.8% of 150% limit, H9-49.9% of 100% limit

California Instruments
San Diego, California

Current Test Result Summary (Replay)

EUT: ENERGY RECOVERY VENTILATOR
 Test category: Class-A (European limits)
 Test date: 2025/11/19 Start time: 17:06:46 End time: 17:09:27
 Test duration (min): 2.5 Data file name: H-001237.cts_data
 Comment: ZX102501
 Customer: Max power

Tested by: George Wu
 Test Margin: 100

Test Result: Pass Source qualification: Normal
 THCA: 0.904 I-THD(%): 128.4 POHC(A): 0.054 POHC Limit(A): 0.251

Highest parameter values during test:

V_RMS (Volts): 230.46	Frequency(Hz): 50.00
I_Peak (Amps): 3.461	I_RMS (Amps): 1.156
I_Fund (Amps): 0.704	Crest Factor: 3.009
Power (Watts): 162.0	Power Factor: 0.610

Harm#	Harms(avg)	100%Limit	%of Limit	Harms(max)	150%Limit	%of Limit	Status
2	0.003	1.080	N/A	0.005	1.620	N/A	Pass
3	0.626	2.300	27.2	0.634	3.450	18.4	Pass
4	0.002	0.430	N/A	0.003	0.645	N/A	Pass
5	0.498	1.140	43.7	0.504	1.710	29.5	Pass
6	0.001	0.300	N/A	0.002	0.450	N/A	Pass
7	0.345	0.770	44.8	0.350	1.155	30.3	Pass
8	0.001	0.230	N/A	0.001	0.345	N/A	Pass
9	0.199	0.400	49.9	0.203	0.600	33.8	Pass
10	0.001	0.184	N/A	0.001	0.276	N/A	Pass
11	0.091	0.330	27.7	0.094	0.495	18.9	Pass
12	0.001	0.153	N/A	0.001	0.230	N/A	Pass
13	0.047	0.210	22.3	0.048	0.315	15.3	Pass
14	0.001	0.131	N/A	0.001	0.197	N/A	Pass
15	0.048	0.150	31.9	0.049	0.225	21.6	Pass
16	0.000	0.115	N/A	0.001	0.173	N/A	Pass
17	0.041	0.132	31.0	0.042	0.198	21.1	Pass
18	0.000	0.102	N/A	0.001	0.153	N/A	Pass
19	0.028	0.118	23.5	0.029	0.178	16.1	Pass
20	0.000	0.092	N/A	0.001	0.138	N/A	Pass
21	0.023	0.107	21.2	0.023	0.161	14.4	Pass
22	0.000	0.084	N/A	0.001	0.125	N/A	Pass
23	0.023	0.098	23.4	0.023	0.147	15.9	Pass
24	0.000	0.077	N/A	0.001	0.115	N/A	Pass
25	0.021	0.090	22.9	0.021	0.135	15.6	Pass
26	0.001	0.071	N/A	0.002	0.107	N/A	Pass
27	0.018	0.083	21.3	0.018	0.125	14.8	Pass
28	0.004	0.066	N/A	0.004	0.099	N/A	Pass
29	0.017	0.078	21.8	0.017	0.116	15.0	Pass
30	0.002	0.061	N/A	0.002	0.092	N/A	Pass
31	0.016	0.073	21.4	0.016	0.109	14.7	Pass
32	0.004	0.058	N/A	0.004	0.086	N/A	Pass
33	0.014	0.068	19.9	0.014	0.102	13.8	Pass
34	0.001	0.054	N/A	0.001	0.081	N/A	Pass
35	0.013	0.064	19.4	0.013	0.096	13.3	Pass
36	0.000	0.051	N/A	0.001	0.077	N/A	Pass
37	0.011	0.061	18.6	0.012	0.091	12.8	Pass
38	0.000	0.048	N/A	0.001	0.073	N/A	Pass
39	0.009	0.058	15.9	0.009	0.087	10.9	Pass
40	0.001	0.046	N/A	0.001	0.069	N/A	Pass

California Instruments
San Diego, California

Voltage Source Verification Data (Replay)

EUT: ENERGY RECOVERY VENTILATOR
 Test category: Class-A (European limits)
 Test date: 2025/11/19
 Test duration (min): 2.5
 Comment: ZX10250I
 Customer: Max power

Tested by: George Wu
 Test Margin: 100
 Start time: 17:06:46
 End time: 17:09:27
 Data file name: H-001237.cts_data

Test Result: Pass Source qualification: Normal

Highest parameter values during test:

Voltage (Vrms): 230.46
 I_Peak (Amps): 3.461
 I_Fund (Amps): 0.704
 Power (Watts): 162.0

Frequency(Hz): 50.00
 I_RMS (Amps): 1.156
 Crest Factor: 3.009
 Power Factor: 0.610

Harm#	Harmonics V-rms	Limit V-rms	% of Limit	Status
2	0.061	0.461	13.33	OK
3	0.548	2.074	26.41	OK
4	0.069	0.461	15.07	OK
5	0.107	0.922	11.63	OK
6	0.034	0.461	7.48	OK
7	0.143	0.691	20.71	OK
8	0.013	0.461	2.87	OK
9	0.075	0.461	16.23	OK
10	0.014	0.461	3.04	OK
11	0.047	0.230	20.30	OK
12	0.015	0.230	6.37	OK
13	0.031	0.230	13.41	OK
14	0.009	0.230	4.08	OK
15	0.028	0.230	12.00	OK
16	0.007	0.230	3.15	OK
17	0.032	0.230	14.10	OK
18	0.007	0.230	3.16	OK
19	0.030	0.230	13.01	OK
20	0.035	0.230	15.07	OK
21	0.023	0.230	9.83	OK
22	0.005	0.230	2.38	OK
23	0.022	0.230	9.71	OK
24	0.003	0.230	1.11	OK
25	0.024	0.230	10.30	OK
26	0.003	0.230	1.34	OK
27	0.018	0.230	7.97	OK
28	0.003	0.230	1.41	OK
29	0.025	0.230	10.68	OK
30	0.003	0.230	1.29	OK
31	0.021	0.230	9.12	OK
32	0.002	0.230	1.00	OK
33	0.018	0.230	7.70	OK
34	0.003	0.230	1.14	OK
35	0.017	0.230	7.52	OK
36	0.003	0.230	1.24	OK
37	0.019	0.230	8.36	OK
38	0.003	0.230	1.43	OK
39	0.019	0.230	8.25	OK
40	0.020	0.230	8.67	OK

California Instruments
San Diego, California

Flicker Test Summary per IEC61000-3-3:2013+A1:2017+A2:2021 (Run time)

EUT: ENERGY RECOVERY VENTILATOR
 Test category: All parameters (European limits)
 Test date: 2025/11/18
 Test duration (min): 120
 Comment: ZX10250I
 Customer: Auto mode

Tested by: George Wu
 Test Margin: 100
 Start time: 9:03:07
 End time: 11:04:41
 Data file name: F-001158.cts_data

Test Result: Pass


Status: Test Completed

Pst_i and limit line

European Limits



Plt and limit line




Parameter values recorded during the test:

Vrms at the end of test (Volt):	230.38		
T-max (mS):	0	Test limit (mS):	500.0 Pass
Highest dc (%):	0.00	Test limit (%):	3.30 Pass
Highest dmax (%):	0.00	Test limit (%):	4.00 Pass
Highest Pst (10 min. period):	0.170	Test limit:	1.000 Pass
Highest Plt (2 hr. period):	0.146	Test limit:	0.650 Pass



Guangdong Future Test Services co., Ltd.
 Tel: +86-760-22185188
 Fax: +86-760-22582768

Conducted Emission Measurement



Site: LAB Phase: **N** Temperature: 23.6
 Limit: EN55014-1 Conduction(QP) Power: AC230V/50Hz Humidity: 42 %
 EUT: ENERGY RECOVERY VENTILATOR Atmosphere Pressure: 101.1KPa
 M/N: ZX10250I
 Mode: max power
 Note:

No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV	Limit dBuV	Over dB	Detector	Comment
1		0.4009	26.44	20.07	46.51	57.83	-11.32	QP	
2		0.4009	20.51	20.07	40.58	48.39	-7.81	AVG	
3		0.7214	26.80	19.76	46.56	56.00	-9.44	QP	
4	*	0.7214	20.51	19.76	40.27	46.00	-5.73	AVG	
5		1.2524	24.39	19.32	43.71	56.00	-12.29	QP	
6		1.2524	19.17	19.32	38.49	46.00	-7.51	AVG	
7		2.2829	24.65	19.30	43.95	56.00	-12.05	QP	
8		2.2829	18.64	19.30	37.94	46.00	-8.06	AVG	
9		3.7770	24.52	19.35	43.87	56.00	-12.13	QP	
10		3.7770	19.53	19.35	38.88	46.00	-7.12	AVG	
11		14.2305	26.98	19.60	46.58	60.00	-13.42	QP	
12		14.2305	20.54	19.60	40.14	50.00	-9.86	AVG	


*:Maximum data x:Over limit !:over margin (Reference Only)



Guangdong Future Test Services co., Ltd.
 Tel: +86-760-22185188
 Fax: +86-760-22582768

Conducted Emission Measurement

File :1 Data :#20 Date: 2025/11/17 Time: 2:04:45



Site LAB Phase: **L1** Temperature: 23.6
 Limit: EN55014-1 Conduction(QP) Power: AC230V/50Hz Humidity: 42 %
 EUT: ENERGY RECOVERY VENTILATOR Atmosphere Pressure: 101.1KPa
 M/N: ZX10250I
 Mode: max power
 Note:

No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV	Limit dBuV	Over dB	Detector	Comment
1		0.3704	28.73	20.05	48.78	58.49	-9.71	QP	
2	*	0.3704	22.33	20.05	42.38	49.24	-6.86	AVG	
3		0.7844	26.01	19.66	45.67	56.00	-10.33	QP	
4		0.7844	18.53	19.66	38.19	46.00	-7.81	AVG	
5		1.3964	24.25	19.28	43.53	56.00	-12.47	QP	
6		1.3964	18.02	19.28	37.30	46.00	-8.70	AVG	
7		2.9985	23.67	19.37	43.04	56.00	-12.96	QP	
8		2.9985	19.56	19.37	38.93	46.00	-7.07	AVG	
9		4.7310	23.78	19.39	43.17	56.00	-12.83	QP	
10		4.7310	17.84	19.39	37.23	46.00	-8.77	AVG	
11		15.5040	26.49	19.66	46.15	60.00	-13.85	QP	
12		15.5040	21.68	19.66	41.34	50.00	-8.66	AVG	

*:Maximum data x:Over limit !:over margin (Reference Only)

File :1Data :#20


Page: 1

Engineer Signature:



Guangdong Future Test Services co., Ltd.
 Tel: +86-760-22185188
 Fax: +86-760-22582768

Conducted Emission Measurement



Site LAB Phase: Temperature: 24
 Limit: EN55014 Current clamp (QP) Power: AC230V/50Hz Humidity: 52 %
 EUT: ENERGY RECOVERY VENTILATOR Atmosphere Pressure: 101.1KPa
 M/N: ZX10250I
 Mode: max power
 Note:

No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuA	Limit dBuA	Over dB	Detector	Comment
1		0.1590	19.78	4.18	23.96	39.52	-15.56	QP	
2	*	0.1590	14.45	4.18	18.63	29.52	-10.89	AVG	
3		0.3030	20.34	-1.46	18.88	34.16	-15.28	QP	
4		0.3030	12.47	-1.46	11.01	24.16	-13.15	AVG	
5		0.5279	18.79	-5.15	13.64	30.00	-16.36	QP	
6		0.5279	12.65	-5.15	7.50	20.00	-12.50	AVG	
7		0.7755	19.34	-7.05	12.29	30.00	-17.71	QP	
8		0.7755	13.33	-7.05	6.28	20.00	-13.72	AVG	
9		1.3334	19.19	-8.50	10.69	30.00	-19.31	QP	
10		1.3334	12.62	-8.50	4.12	20.00	-15.88	AVG	
11		1.8239	19.59	-9.09	10.50	30.00	-19.50	QP	
12		1.8239	12.52	-9.09	3.43	20.00	-16.57	AVG	


*:Maximum data x:Over limit !:over margin (Reference Only)



Guangdong Future Test Services co., Ltd.
 Tel: +86-760-22185188
 Fax: +86-760-22582768

Disturbance Power Measurement

File :1 Data :#18 Date: 2025/11/16 Time: 1:01:27



Site LAB Temperature: 24
 Limit: EN55014-1 Clamp(QP) Humidity: 52 %
 EUT: ENERGY RECOVERY VENTILATOR Power: AC230V/50Hz Atmosphere Pressure: 101.1KPa
 M/N: ZX102501
 Mode: max power
 Note: control line near ENERGY RECOVERY VENTILATOR

No.	Mk.	Freq.	Reading Level	Correct Factor	Measurement	Limit	Over	Detector	Position
		MHz	dBpW	dB	dBpW	dBpW	dB		cm
1		40.3800	9.73	25.42	35.15	45.40	-10.25	QP	
2	*	40.3800	-0.04	25.42	25.38	35.38	-10.00	AVG	
3		70.0199	-1.94	23.90	21.96	46.53	-24.57	QP	
4		70.0199	-11.03	23.90	12.87	36.48	-23.61	AVG	
5		82.7400	-3.92	24.14	20.22	47.02	-26.80	QP	
6		82.7400	-12.95	24.14	11.19	36.95	-25.76	AVG	
7		130.7400	-1.40	23.99	22.59	48.85	-26.26	QP	
8		130.7400	-10.55	23.99	13.44	38.73	-25.29	AVG	
9		142.2000	1.67	23.86	25.53	49.29	-23.76	QP	
10		142.2000	-9.04	23.86	14.82	39.16	-24.34	AVG	
11		156.9000	-2.52	23.84	21.32	49.85	-28.53	QP	
12		156.9000	-10.42	23.84	13.42	39.70	-26.28	AVG	

*:Maximum data x:Over limit !:over margin (Reference Only)

Final Factor=probe factor+Cable loss.

File :1\Data :#18

Page : 1

Engineer Signature:


Model: ZX10190I



Picture 1




Picture 2




Picture 3



Picture 4



Picture 5



Picture 6

Model: ZX10250I



Picture 7



Picture 8



Picture 9



Picture 10




Picture 11



Picture 12




Picture 13



Picture 14




Picture 15



Picture 16




Picture 17




Picture 18




Picture 19



Picture 20




Picture 21




Picture 22




Picture 23




Picture 24




Picture 25




Picture 26



Picture 27



Picture 28




Picture 29




Picture 30



Picture 31



Picture 32



Picture 35

Harmonics & Flicker					<input checked="" type="checkbox"/>
Equipment	Manufacturer	Model No.	Serial No.	Cal Until	
Harmonic and Flicker Analyzer	CI	100-CTS-230	1636A01855	25 Jul, 2026	
AC Power Source	CI	5001IX-CTS-400-413-411	1638A03444	25 Jul, 2026	
Disturbance Voltage					<input checked="" type="checkbox"/>
Equipment	Manufacturer	Model No.	Serial No.	Cal Until	
EMI Test Receiver	R&S	ESCI3	1166.5950.03	25 Jul, 2026	
Shield Room	YiHeng Electronics	13x4.1x3.1	ZS-YF002	25 Jul, 2028	
Conducted Emission Software	FALA	EZ-EMC	N/A	N/A	
Artificial Mains Network	R&S	ENV216	102609	25 Jul, 2026	
10dB Attenuator	SCHWARZBEC K	VTSD 9561	0357.8810.54-102774-NB	25 Jul, 2026	
Discontinuous Disturbance Voltage					<input checked="" type="checkbox"/>
Equipment	Manufacturer	Model No.	Serial No.	Cal Until	
Click Analyzer	AFJ	CL55C	55041220164	19 Feb, 2026	
Artificial Mains Network	SCHWARZBEC K	NSLK8127	8127640	25 Jul, 2026	
Disturbance Power					<input checked="" type="checkbox"/>
Equipment	Manufacturer	Model No.	Serial No.	Cal Until	
EMI Test Receiver	R&S	ESCI3	1166.5950.03	25 Jul, 2026	
Absorbing Clamp	SCHWARZBEC K	MDS-21	03001	20 Feb, 2026	
Conducted Susceptibility(150 kHz-230 MHz)					<input checked="" type="checkbox"/>
Equipment	Manufacturer	Model No.	Serial No.	Cal Until	
Conducted Immunity Test System	SCHLODER	CDG 6000-75	19901990-0101	19 Feb, 2026	
6dB Attenuator	SCHLODER	CDG 6050-100	3101	19 Feb, 2026	
Coupling Decoupling Network	SCHLODER	CDN M2/M3	19901991-0201	19 Feb, 2026	
Electrical Fast Transient(EFT)					<input checked="" type="checkbox"/>

Equipment	Manufacturer	Model No.	Serial No.	Cal Until
Transient comprehensive immunity test device	HTEC Test	HCOMPACT 52	190401	19 Feb, 2026
Three-phase coupled decoupling network	HTEC Test	HCOUPLER 30E	195201	19 Feb, 2026
Single phase regulator	HTEC Test	HV1P16T	190301	19 Feb, 2026
Surge <input checked="" type="checkbox"/>				
Equipment	Manufacturer	Model No.	Serial No.	Cal Until
Surge Generator	HTEC Test	HCWG 100	164201	25 Jul, 2026
Three-phase coupled decoupling network	HTEC Test	HCOUPLER 30S	164202	25 Jul, 2026
Voltage dips and Interruption <input checked="" type="checkbox"/>				
Equipment	Manufacturer	Model No.	Serial No.	Cal Until
Transient comprehensive immunity test device	HTEC Test	HCOMPACT 52	190401	19 Feb, 2026
Three-phase coupled decoupling network	HTEC Test	HCOUPLER 30E	195201	19 Feb, 2026
Single phase regulator	HTEC Test	HV1P16T	190301	19 Feb, 2026
Electrostatic Discharge <input checked="" type="checkbox"/>				
Equipment	Manufacturer	Model No.	Serial No.	Cal Until
ESD Simulator	TESEQ	NSG 437	536	02 Aug, 2026

-----End of test report-----